



10 APR 14 P1 57

STATE PROCUREMENT OFFICE
EMERGENCY PROCUREMENT REQUEST
STATE PROCUREMENT OFFICE
STATE OF HAWAII

1. TO: Chief Procurement Officer
2. FROM: Department of Hawaiian Home Lands

Department/Division/Agency

Pursuant to §103D-307, HRS, and Subchapter 10, Chapter 3-122, HAR, the Department requests approval for the following:

3. Date 3/29/2010

4. After the fact ☒ YES ☐ NO

5. Nature of the Emergency

There are 4 out of 6 inoperable hydropneumatic tanks at the Leialii Well Pump Site. The purpose of the tanks is to keep the well pump from cycling on and off and cushion the system from pressure hammer when the Well pump starts and stops. If the 4 inoperable tanks are not replaced there is a high risk of loss of water for the community.

6. Vendor: Water Controls, Inc.
Address: 3685 Lower Kula Road
Kula, Hawaii 96790

7. Price:
\$6,609.07

8. Description of goods, services, or construction to be purchased

Purchase and replace the 4 inoperable hydropneumatic tanks at the Leialii Well Pump Site. This includes materials, **shipping and labor.**

9. Reason for Vendor Selection

This vendor is already working on the site to maintain the water pump system.

10. Direct questions to: ~~Patrick Young~~ ^{KQ} Kehaulani Quartero

Phone: 620-9287

11. I certify that the information provided above is to the best of my knowledge, true and correct.

Department Head

Date

Reserved for SPO Use Only

12. Chief Procurement Officer's comments:

Pursuant to Procurement Delegation No. 2008-01, emergency procurements less than \$50,000 may be approved by the department head and do not require CPO approval. However, emergency procurements \$2,500 or more are required to be posted on the Procurement Reporting System.

For the above reason, this request is returned with no action required by the State Procurement Office.

13.

☐ APPROVED ☐ DISAPPROVED ☒ NO ACTION REQUIRED

James S. Jett 4/15/2010
Chief Procurement Officer Date

14. E.P.No.

10-022-D